



# GVFCA MOBILE FOOD VENDORS CHECKLIST

Version 1.

## MULTI-JURISDICTIONAL INSPECTION CHECKLIST

This checklist is to be used in conjunction with the GVFCA *Mobile Food Vendors - Acceptable Guidelines* for inspecting and approving any mobile unit used outdoors to prepare and dispense food and/or beverages and that contain appliances or equipment for cooking.

- TRUCK                                       TRAILER                                       CART  
 Public Primary                                       Film Primary

### FOOD VENDOR UNIT INFORMATION:

Applicant Name: \_\_\_\_\_ City: \_\_\_\_\_

Phone: \_\_\_\_\_ E-mail: \_\_\_\_\_

Truck Name: \_\_\_\_\_ Plate: \_\_\_\_\_

Vehicle Make: \_\_\_\_\_ VIN #: \_\_\_\_\_

GENERAL REQUIREMENTS:	Pass	Fail	N/A
Business License to operate (if required by jurisdiction).	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Clear and unobstructed egress from interior.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Traffic safety cones (min 3 cones @ 18").	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
All portable tents and attached awnings/fabrics as part of food preparation shall have flame resistance conforming to CAN/ULC S109 as identified by a factory label.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>

TECHNICAL SAFETY BC / STANDARDS COUNCIL of CANADA:	Pass	Fail	N/A
Approved Certification Commercial Gas Systems (TSBC D-G5-051201 2)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Approved Certification 120 VAC Electrical Systems (TSBC B-E3 071019 3)	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Notes:			

FIRE EXTINGUISHERS: (as per NFPA 10)	Pass	Fail	N/A
10lb ABC, 4A-40BC Mounted, accessible, current service.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Class K Wet Chemical (oil cooking or deep fryer present) mounted, accessible, current service.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Pull Station for fixed suppression visible and accessible.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Notes:			
ASTTBC Next Service Due: _____			



# GVFCA MOBILE FOOD VENDORS CHECKLIST

Version 1.

## MULTI-JURISDICTIONAL INSPECTION CHECKLIST

<b>COOKING AND SERVICE:</b>	Pass	Fail	N/A
All commercial cooking units that create grease laden vapors (deep fryers, burners, grills etc.) inside trailers or trucks shall have an automatic suppression systems meeting ANSI/UL300 or ULC/ORD-C 1254.6 and a commercial ventilation system installed utilizing good engineering practice.*	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Fixed Suppression complete with current service (6 months) nozzles/pull activation/bell.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Kitchen exhaust hood – filters, cleaned and current service (6 months).	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
8” baffle or 16” clearance between fryer and open flame cook top.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Notes:			
ASTTBC Next Service Date: _____			

<b>GENERATOR / FUEL / PROPANE: As per Annex J of CSA B149.3 (20)</b>	Pass	Fail	N/A
Generator in good repair including cords rated for use (grounding intact).	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Portable fuel cans stored outside of truck & 1m away from ignition sources.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Fixed propane tanks secured to vehicle (leak test? PRV away from crowds).	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Unattached propane tanks storage NOT permitted in vehicles.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Notes:			

<b>SOLID FUEL COOKING (not permitted in all jurisdictions):</b>	Pass	Fail	N/A
Level 1 WETT service for solid fueled ovens and flues (wood fired pizza etc.).	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Fuel is NOT stored closer than 1m from cooking appliance or heat source.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
2A Water Type or 6L Wet Chemical – current service.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Notes:			

**NOTES:**

All outside cooking associated with truck to be on stable approved non-combustible base (as per AHJ).

NO oils or deep frying on collapsible tables (folding legs).

Portable generators to be filled prior to use and kept 1m away from heat source.

\* Exhaust hoods will be inspected and approved at the discretion of the AHJ

PASS:  FAIL:  DECAL #: \_\_\_\_\_

Inspecting Jurisdiction: \_\_\_\_\_ DATE: \_\_\_\_\_

Fire Inspector: \_\_\_\_\_ *Name or employee number or LAFC* Phone #: \_\_\_\_\_

Truck Owner / Rep: \_\_\_\_\_ *Signature* DATE: \_\_\_\_\_

X \_\_\_\_\_ Initials hereby indicate acceptance that the information within this inspection report may be shared with GVFCA fire department representatives.

**A copy of this Checklist is to be kept in the vehicle at all times**